A close-up photograph of a person's hands holding a clear glass under a running faucet. Water is being poured into the glass, creating bubbles. The background is blurred, showing a kitchen sink and countertop. A blue banner is overlaid on the top of the image, containing the title text.

# **BURNABY DRINKING WATER QUALITY 2021 ANNUAL REPORT**





## TABLE OF CONTENTS

<b>INTRODUCTION</b>	5
<b>REGULATORY CONTEXT</b>	5
Provincial/Federal Regulatory Requirements	5
Regional Health Authority Requirements	5
Metro Vancouver Requirements	5
<b>DRINKING WATER SYSTEM</b>	7
Source and Transmission Water Quality Monitoring	7
Source Water Quality Reporting	7
Water Conservation	9
Distribution System	11
Infrastructure	11
Cross Connection Control Program	11
<b>WATER QUALITY MONITORING PROGRAM</b>	13
Physical Parameters	17
Chemical Parameters	19
Bacteriological Quality	22
<b>WATER UTILITY INCIDENT RESPONSE PLAN</b>	24
<b>CONCLUSION</b>	25



## FIGURES

- Figure 1 [How Do You Use Your Water?](#)
- Figure 2 [Burnaby Drinking Water Quality Monitoring Stations Map](#)
- Figure 3 [Number of Monthly Routine Samples Taken in 2021](#)
- Figure 4 [2021 Average Monthly Water Temperatures in the Distribution System](#)
- Figure 5 [2021 Monthly Average Turbidity Levels in the Distribution System](#)
- Figure 6 [Improvements in Drinking Water Distribution System \(1997-2021\)](#)
- Figure 7 [City of Burnaby – Results of Bacteriological Analyses of Potable Water Samples Compliance with BC Drinking Water Protection Regulation Provided by Metro Vancouver](#)

## TABLES

- Table 1 [Schedule B \(Frequency of Monitoring Samples for Prescribed Water Supply Systems\) of the B.C. Drinking Water Protection Regulation](#)
- Table 2 [Burnaby Drinking Water Disinfection By-Products Results \(2021\)](#)
- Table 3 [Burnaby Drinking Water Total Metal Sampling Results \(2021\)](#)
- Table 4 [Schedule A \(Water Quality Standards For Potable Water\) of the B.C. Drinking Water Protection Regulation](#)

## APPENDICES

- Appendix A [Detailed Water Quality Reports of Samples Collected in 2021](#)
- Appendix B [Metro Vancouver Water Quality Control Annual Report for 2021](#)





Metro Vancouver Seymour-Capilano Filtration Plant Source: Metro Vancouver



## INTRODUCTION

This report provides an overview of the regulatory context and outlines the drinking water quality program for 2021 and associated sample results to provide evidence of potability and compliance with the *British Columbia Drinking Water Protection Regulation*.

## REGULATORY CONTEXT

Drinking water in the City of Burnaby (the City) falls under the regulatory jurisdiction of several government agencies:

### Provincial/Federal Regulatory Requirements

The *British Columbia Drinking Water Protection Regulation* promulgated under the *Drinking Water Protection Act* requires, amongst other aspects, suppliers of drinking water in British Columbia to hold an operating permit, demonstrate that the drinking water is appropriately treated and monitored from a microbial perspective, have appropriate emergency and public notification plans in place, and prepare and make public an annual report on the results of the previous year. In addition, the *Federal Guidelines for Canadian Drinking Water Quality* provide references for acceptable concentration values for various microbial, chemical and physical parameters for potable water.

### Regional Health Authority Requirements

In 2000, a *Water Quality Monitoring and Reporting Plan for the GVRD and Member Municipalities (WQMRP)* was established by the Regional Medical Health Officials, the Greater Vancouver Water District and member municipalities. This document, which was reviewed and amended in January 2006, is a cornerstone in providing regional consistency in the monitoring and reporting of bacteriological and chemical drinking water quality parameters. In order to avoid duplication, the WQMRP separates the responsibilities for water quality monitoring and reporting between Metro Vancouver and the member municipalities by generally assigning the responsibility of source water monitoring and reporting to Metro Vancouver and the responsibility for distribution system monitoring and reporting to the municipalities.

### Metro Vancouver Requirements

In addition to the WQMRP, *The Drinking Water Management Plan (DWMP)* was adopted in 2005 to ensure that our region's water needs will be met affordably and sustainably for Metro Vancouver and its member municipalities. In 2007, the Plan was amended to fully incorporate management of the source watersheds. In June 2011, the Plan was updated again to detail the investments in water treatment, supply and conservation programs necessary to provide consistently high-quality drinking water, improved supply reliability, and greater environmental protection. A progress report was published in 2014 which outlines the steps implemented by Metro Vancouver to meet the goals and objectives set out in the 2011 plan. Details of the Plan and the municipal actions identified and adopted by the City are posted on the Metro Vancouver website at: [metrovancover.org](http://metrovancover.org)







## DRINKING WATER SYSTEM

Metro Vancouver draws its water from Capilano, Seymour and Coquitlam reservoirs, and distributes it through its waterworks systems to member municipalities after treatment. Metro Vancouver uses filtration, UV and chlorine to treat the Seymour and Capilano source waters at the Seymour-Capilano Filtration Plant (SCFP) which opened in 2009. Coquitlam source water uses ozone for pre-treatment and UV and chlorine as primary disinfectants. The source waters are then subsequently re-chlorinated at various regional secondary disinfection facilities (eight stations located throughout Metro Vancouver) installed in 1998. The disinfectant dosages are monitored at the regional chlorination facilities using on-line chlorine meters.

### Source and Transmission Water Quality Monitoring

Metro Vancouver undertakes comprehensive biological and chemical monitoring of the water while it is in their system. At the intake, the following parameters are tested as outlined in the WQMRP: Total Coliforms, *E. Coli*, Heterotrophic Plate Count (HPC), turbidity, pesticides, herbicides, all chemical parameters listed in the *Guidelines for Canadian Drinking Water Quality*, and protozoans (*Giardia* and *Cryptosporidium*).

In the transmission mains and reservoirs, Metro Vancouver also samples and tests the drinking water for indicator organisms (Total Coliforms, *E. Coli*, and HPC), and a limited number of chemicals (free chlorine residual, polycyclic aromatic hydrocarbons (PAHs) and Benzene, Toluene, Ethylbenzene, Xylene (BTEX)). The 2020 water quality results for Capilano, Seymour and Coquitlam watersheds can be found in Appendix B.

### Source Water Quality Reporting

Metro Vancouver staff presented their annual report on 2021 source water quality to the Metro Vancouver Utilities Committee on April 6, 2022 to demonstrate their compliance with the BC Drinking Water Protection Regulation and the regional health authorities' requirements. A summary and highlights of the region's water quality monitoring for 2021 can be found in their publication "*The Greater Vancouver Water District Quality Control Annual Report 2021, Volume I*", (Appendix B). Volume II of the report provides a full tabulation of data for both chemical and physical monitoring results. In an effort to reduce paper usage, the printing of Volume II has been limited by Metro Vancouver but can be made available, if requested, either in hard copy or electronically. Requests for Volume II should be directed to the Water Quality Information Line at 604-451-6010. This publication will be posted on Metro Vancouver's website [metrovancouver.org](https://www.metrovancouver.org) by the end of June 2022.



### Water Conservation in a Rainforest?

Metro Vancouver gets a lot of rain throughout the year (over one metre per year in some regions) except during the months of July, August and September. These are also the months during which water demand increases, in part, due to watering our lawns which can create a shortage of fresh drinking water. A healthy lawn needs only one hour of rain or watering per week. Metro Vancouver's Drinking Water Conservation Plan describes watering restrictions that are in place from May 1 to October 15 annually. This Plan helps to conserve water in the summer months, when we use water faster than our reservoirs can refill. More details on lawn watering restrictions are available at [Burnaby.ca/WaterRestrictions](http://Burnaby.ca/WaterRestrictions).








Figure 1 – How Do You Use Your Water? Data from Metro Vancouver

## Water Conservation

Here in Burnaby, surrounded by waterways and with our mild, wet winters, it's easy to forget that water is a precious and limited resource. On average, Metro Vancouver residents use about 270 litres per day for activities such as showering, washing dishes, clothes, and flushing toilets (Figure 1). With our climate and accessible resources, it's easy to take water for granted.

### Water conservation is important for:

- » Ensuring sufficient drinking water supply throughout the year particularly when low snow-pack levels along with hot summers prevent our reservoirs from a full recharge. The Capilano, Seymour and Coquitlam reservoirs are filled by precipitation and snowmelt.
- » Meeting the demands of a growing population and delaying (or eliminating) the need for costly upgrades in the future.
- » Reducing waterfront pollution by minimizing how much waste water is generated.

Our water use can increase by up to 50 per cent during the summer months, largely due to lawn watering and other outdoor uses. The City of Burnaby encourages residents to use water sustainably to protect our water supply, conserve energy, and help reduce personal utility costs. Water use can typically be reduced with a few simple changes to both your indoor and outdoor water use:


- » Turn off the tap while brushing your teeth or washing dishes.
- » Take shorter showers. Reducing your shower by two minutes can save 15 litres of water per day.
- » Wash full loads and use shorter cycles when doing laundry. This saves 95 litres of water per load.
- » Save the water you use while rinsing fruit and vegetables for watering house plants.
- » Use dual-flush or low-flow toilets to save 6 to 14 litres of water per flush.
- » Use aerator and flow restrictors on the kitchen tap to save up to 20 litres of water per day.
- » Fix leaks in kitchen and bathroom taps.
- » An hour a week of sprinkling or rain is all you need for a healthy lawn. This saves up to 17,000 litres of water per household over the summer months.
- » Use spring-loaded garden hose nozzles. This saves 23 litres of water per minute.
- » Water your lawn early in the morning to reduce the amount of water lost to wind and evaporation.
- » Use a broom instead of a hose to sweep driveways, decks, patios and sidewalks.





Pump Station





## Distribution System

The City receives its treated water from Metro Vancouver and distributes it to consumers through a series of reservoirs and a network of pipes. In order to ensure potability of the water at the point of use, the City has a comprehensive program consisting of water quality monitoring, routine uni-directional flushing of watermains, cross-connection control and reservoir exercising.

## Infrastructure

The City's water system consists of four water pump (or booster) stations, four active water storage reservoirs (storage capacity 13.0 ML), twenty-two (22) pressure reducing stations, twenty-one (21) pressure zones and over 710 km of watermains valued at over \$490 million.

The City has a watermain replacement program (average age of pipe is 29 years) to replace aging watermains at a rate of nearly 2 per cent a year (approximately 12 to 14 km per year), and a program to install and maintain dedicated sampling kiosks at sampling locations.

## Cross-Connection Control Program

The City's cross-connection control program is in place to ensure the potable water supply is protected from contamination in the event of back siphonage or back pressure. The City requires that appropriate backflow preventers are installed and tested annually as prescribed in the City of Burnaby Plumbing Bylaw #11148. Regulations for the cross connection control can be found in the British Columbia Plumbing Code. Further information on the City's cross-connection control program can be obtained directly from the Burnaby Building Department – Plumbing and Gas Inspections at 604-294-7130.





Drinking Water Sampling





## WATER QUALITY MONITORING PROGRAM

In 2021, there were 63 water quality sample locations in Burnaby (Figure 2 and Appendix A). These sample locations were selected on the basis of determining water quality in various pressure zones, dead ends, reservoirs, feed lines from Metro Vancouver watermains, residences and institutions. These locations were grouped into four different routes for sample collection purposes. Water samples were collected on average twice per week on a two week sample location cycle. At the time of sample collection, free chlorine residual and temperature were measured using field test kits. In addition, Metro Vancouver collected water samples from 14 sites along its transmission network in the City (Figure 2 and Appendix A).

The collected samples were submitted to the Metro Vancouver Laboratory for analysis. The Metro Vancouver Laboratory is a member of the Canadian Association of Environmental Analytical Laboratories (CAEAL), is accredited by the Standards Council of Canada (SCC) and is also approved by the Provincial Medical Health Officer for potable water testing.

A total of 2,515 routine drinking water samples were obtained in 2021 for bacteriological analysis. These included 1,604 samples collected from City sample sites and 911 samples collected from Metro Vancouver transmission line sites located within the City boundary (Appendix A). The average number of samples collected for bacterial monitoring by the City every month was over 130 (Figure 3). Based on Burnaby's projected population of around 249,125, this is above the 107 monthly sample requirement stipulated in the BC Drinking Water Protection Regulation for Burnaby's population size (Figure 3 and Table 1).

From a reporting perspective, Fraser Health Authority (FHA) was provided with the drinking water quality results directly by the Metro Vancouver laboratory at the same time as the results were sent to the City. It is to be noted that information regarding sampling locations, sample frequency, sample collection methodology, sample parameters and the laboratory to be used for sample analysis were submitted and accepted by FHA. Furthermore, FHA also collects water samples from City kiosks for audit purposes on a regular basis.



# Burnaby Drinking Water Quality Monitoring Stations 2021



Figure 2 – Burnaby Drinking Water Quality Monitoring Stations Map






Figure 3 – Number of Monthly Routine Samples Taken in 2021

<b>TABLE 1:            SCHEDULE B (FREQUENCY OF MONITORING SAMPLES            FOR PRESCRIBED WATER SUPPLY SYSTEMS) OF THE            B.C. DRINKING WATER PROTECTION REGULATION</b>	
Population Served	Number of Samples Per Month
Less than 5,000	4
5,000 to 90,000	1 per 1,000 of population
More than 90,000	90 plus 1 per 10,000 of population in excess of 90,000






Figure 4 – 2021 Average Monthly Water Temperatures in the Distribution System




Figure 5 – 2021 Monthly Average Turbidity Levels in the Distribution System



## Physical Parameters

In the City's water distribution system, the physical parameters tested include temperature and turbidity.

### Temperature


Water temperature in the distribution system is dependent on the seasonal temperature variation experienced by the source water. The *Guidelines for Canadian Drinking Water Quality* set the aesthetic objective (AO) at less than 15°C for drinking water temperature. Temperatures above 15°C can impact aesthetic properties of taste, colour and odour. Temperature is also related to the microbiological characteristics of drinking water through its effect on water treatment processes, especially disinfection, and its effect on the growth and survival of micro-organisms.

The average water temperature in the distribution system remained well below the AO of 15°C throughout the year other than July, August and September (Figure 4). This was due to Metro Vancouver experiencing an unprecedented heat dome phenomena in late June and early July when daytime high temperatures reached over 40°C when adjusted with the humidex index. However, during this period, water quality samples did not show an increase in bacteriological growth, indicating that effective water treatment such as filtration and chlorine disinfection was achieved.

### Turbidity

Turbidity is a measure of the relative clarity or cloudiness of water caused by fine suspended matter such as clay, silt and organics. Turbidity is not a direct measure of these particles, but rather a general measure of the effect these particles have on light. Elevated turbidity may be attributed to source water conditions or other transient activities which cause a change in water pressure or flow in the system. These activities include construction, watermain flushing, watermain breaks, or a sudden increase in water usage (i.e. firefighting). In the event that a sample indicated a high turbidity reading, the procedure would be to follow up with the FHA, immediately flush the applicable watermain(s) and re-sample as appropriate.

In 2021, the majority (99.0 per cent) of the water sampled had turbidity less than 1 NTU. Sixteen (16) samples (1.0 per cent) had turbidity greater than 1 NTU. The average turbidity in Burnaby's water system is seasonally constant as shown in Figure 5.



Stock photo - Water Sample Testing




**TABLE 2: BURNABY DRINKING WATER DISINFECTION BY-PRODUCTS RESULTS (2021)**

Sample Site	Sample Date	THM (ppb)						HAA (ppb)						
		Bromodichloromethane	Bromoform	Chlorodibromomethane	Chloroform	Total Trihalomethanes	Total THM Quarterly Average	Dibromoacetic Acid	Dichloroacetic Acid	Monobromoacetic Acid	Monochloroacetic Acid	Trichloroacetic Acid	Total Haloacetic Acid	Total HAA Quarterly Average
BUR-498K	2021-02-26	<1	<1	<1	27	28	35	<0.5	6	<1	<2	7	15	31
	2021-06-07	1	<1	<1	32	34	34	<0.5	17	<1	<2	31	50	35
	2021-08-26	1	<1	<1	31	33	31	<0.5	9	<1	<2	24	34	32
	2021-11-26	<1	<1	<1	28	29	31	<0.5	6	<1	<2	9	16	29
BUR-561K	2021-02-26	<1	<1	<1	19	20	22	<0.5	7	<1	<2	6	14	16
	2021-06-07	<1	<1	<1	19	21	21	<0.5	9	<1	<2	8	19	16
	2021-08-26	1	<1	<1	22	24	21	<0.5	12	<1	<2	6	18	18
	2021-11-26	<1	<1	<1	21	22	22	<0.5	8	<1	<2	6	14	16
BUR-575K	2021-02-26	<1	<1	<1	25	26	28	<0.5	5	<1	<2	3	8	16
	2021-06-07	<1	<1	<1	23	25	27	<0.5	9	<1	<2	8	18	16
	2021-08-26	1	<1	<1	28	30	27	<0.5	10	<1	<2	6	16	16
	2021-11-26	<1	<1	<1	26	27	27	<0.5	6	<1	<2	5	12	14
BUR-584K	2021-02-26	<1	<1	<1	21	22	27	<0.5	5	<1	<2	3	10	29
	2021-06-07	<1	<1	<1	20	22	23	<0.5	10	<1	<2	9	22	24
	2021-08-26	1	<1	<1	30	32	25	<0.5	22	<1	<2	23	45	24
	2021-11-26	<1	<1	<1	24	24	25	<0.5	9	<1	<2	7	16	23
BUR-586K	2021-02-26	<1	<1	<1	30	31	39	<0.5	5	<1	<2	7	13	26
	2021-06-07	<1	<1	<1	31	33	39	<0.5	8	<1	<2	14	23	26
	2021-08-26	1	<1	<1	34	36	34	<0.5	9	<1	<2	10	19	17
	2021-11-26	<1	<1	<1	32	33	33	<0.5	4	<1	<2	9	13	17
BUR-594K	2021-02-26	<1	<1	<1	23	24	29	<0.5	6	<1	<2	5	12	23
	2021-06-07	<1	<1	<1	22	24	27	<0.5	10	<1	<2	10	23	21
	2021-08-26	1	<1	<1	32	35	27	<0.5	15	<1	<2	14	29	20
	2021-11-26	<1	<1	<1	26	27	28	<0.5	10	<1	<2	9	18	20
BUR-856K*	2021-02-26	<1	<1	<1	34	36	45	<0.5	<1	<1	<2	7	9	15
	2021-06-07	1	<1	<1	34	36	41	<0.5	<1	<1	<2	<0.5	<5	10
	2021-08-26	1	<1	<1	48	50	40	<0.5	1	<1	<2	5	7	6
	2021-11-26	<1	<1	<1	41	42	41	<0.5	<1	<1	<2	<0.5	<2.5	6

\*598K has been changed to 856K





## Chemical Parameters

Water in the City's distribution system is also tested for chemical parameters of pH, chlorine, disinfection by-products (Haloacetic Acids and Total Trihalomethanes), metals and vinyl chloride.

### pH

The pH levels of water sampled was representative of the pH levels of the source water except for one location at Burnaby Mountain. The 2 samples collected in August and December had pH levels of 9.4 which is higher than the *Guidelines for Canadian Drinking Water Quality* Aesthetic Objective of 6.5 to 8.5. While pH is an Aesthetic Objective parameter, the City strives to provide the highest quality of water to end users. Work has been done to upgrade the water infrastructure in this location. The end users in this area now receive their water from a new watermain connected to a pressure zone with a much shorter water residence time and a much quicker turnover rate. This will also aid in providing water which will meet the minimum chlorine residual of 0.2 mg/L.

### Chlorine Residual

Chlorine is used to disinfect the water and safeguard against any microbial re-growth or contamination in the distribution system. The *Guidelines for Canadian Drinking Water Quality* recommends a minimum free chlorine residual of 0.2 mg/L.

On average, 97.5 per cent of water samples obtained from the sixty-three (63) sampling stations achieved the objective of 0.2 mg/L or above in 2021 (Appendix A). Of the 2.5% (41) of water samples that had free chlorine residual of <0.2 mg/L, 29 samples were from 2 sample locations. One of the sampling sites is located in a dead-end cul-de-sac with limited water use from the low number of residents living in this area. The City aims to maintain the residual chlorine levels in this area by regular frequent flushing of the watermain to enhance flow. The other sampling site is in Burnaby Mountain. The minimum chlorine residual is not met from samples collected is due to the fact that the water stays for prolonged periods of time in a series of reservoirs before the water is used. Historically, the City has

provided a UV disinfectant system to the end user to treat the water. In 2021, the City made upgrades to the water infrastructure in this area. The end users in this area now receive their water from a new watermain connected to a pressure zone with a much shorter water residence time and a much quicker turnover rate.

### Disinfection By-products

Disinfection by-products are compounds formed by the interaction between chlorine and naturally occurring organic substances in the water such as decaying leaves and vegetation that enter the source water naturally.

The disinfection by-products, measured as Trihalomethanes (THM) and Haloacetic Acid (HAA) were found to be below the Maximum Acceptable Concentration (MAC) value of 100 parts per billion and 80 parts per billion, respectively as noted in the *Guidelines for Canadian Drinking Water Quality* (Table 2).

### Vinyl Chloride

Two (2) Vinyl chloride samples were taken in 2021. The samples were taken at a location where the longest section of poly vinyl chloride (PVC) pipes was installed for conveying drinking water to the end user. The vinyl chloride concentration in each sample was found to be < .001 mg/L which is below the guideline value of 0.002 mg/L stipulated in the *Guidelines for Canadian Drinking Water Quality*.



## Metals

Drinking water samples from (7) seven stations were tested for metals on two different occasions. None of the sample results exceeded the Maximum Acceptable Concentration (MAC) guideline values stipulated in the *Federal Guidelines for Canadian Drinking Water Quality* (Table 3).

**TABLE 3: BURNABY DRINKING WATER TOTAL METAL SAMPLING RESULTS (2021)**

Site		BUR-498K		BUR-561K		BUR-570K		BUR-576K		Guidelines <sup>1</sup>	
Sample Date		22/04/2021	09/11/2021	22/04/2021	09/11/2021	22/04/2021	09/11/2021	22/04/2021	09/11/2021	MAC	AO
Total Metals (µg/L)	Aluminum	56	65	25	49	24	51	21	54	NA	200
	Antimony	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	6	NA
	Arsenic	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	10 (ALARA)	NA
	Barium	2.6	2.9	3.2	2.6	3.2	2.6	3.2	2.6	2000	NA
	Boron	<10	<10	<10	<10	<10	<10	<10	<10	5000	NA
	Cadmium	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	7	NA
	Calcium	2480	6420	4430	7900	4460	7970	4520	8380	NA	NA
	Chromium	<0.05	<0.05	<0.05	<0.05	<0.05	<0.05	<0.05	<0.05	50	NA
	Cobalt	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	NA	NA
	Copper	6.8	4.4	9.6	4.4	12.5	6.2	6.6	2.5	≤2000	NA
	Iron	39	17	10	6	6	5	<5	7	NA	≤ 300
	Lead	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	5 (ALARA)	NA
	Magnesium	141	168	196	179	196	184	196	191	NA	NA
	Manganese	3.5	3.1	11.8	2.0	9.9	1.9	3.1	2.2	120	NA
	Mercury	<0.05	<0.05	<0.05	<0.05	<0.05	<0.05	<0.05	<0.05	1.0	NA
	Molybdenum	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	NA	NA
	Nickel	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	NA	NA
	Potassium	142	144	173	146	176	145	175	145	NA	NA
	Selenium	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	50	NA
	Silver	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	NA	NA
Sodium	4030	3710	1650	1530	1630	1490	1620	1490	NA	≤ 200,000	
Zinc	3.2	4.0	<3.0	3.2	3.9	4.3	<3.0	<3.0	NA	≤ 5000	

**NA** – No Current Guideline Available **MAC** – Maximum Allowable Concentration **AO** – Aesthetic Objective  
**ALARA** – As Low As Reasonably Achievable <sup>1</sup>Canadian Drinking Water Quality Guidelines



**TABLE 3: BURNABY DRINKING WATER TOTAL METAL SAMPLING RESULTS (2021)**

Site		BUR-582K		BUR-586K		BUR-592K		Guidelines <sup>1</sup>	
Sample Date		22/04/2021	09/11/2021	22/04/2021	09/11/2021	22/04/2021	09/11/2021	MAC	AO
Total Metals (µg/L)	Aluminum	22	49	31	55	24	55	NA	200
	Antimony	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	6	NA
	Arsenic	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	10 (ALARA)	NA
	Barium	3.2	2.8	3.2	2.7	3	2.5	2000	NA
	Boron	<10	<10	<10	<10	<10	<10	5000	NA
	Cadmium	<0.2	<0.2	<0.2	<0.2	<0.2	<0.2	7	NA
	Calcium	4430	8210	4390	8010	4470	7910	NA	NA
	Chromium	<0.05	<0.05	<0.05	0.06	<0.05	<0.05	50	NA
	Cobalt	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	NA	NA
	Copper	7.8	3.8	11.9	6.4	11.6	3.7	≤2000	NA
	Iron	<5	5	17	21	<5	6	NA	≤ 300
	Lead	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	5 (ALARA)	NA
	Magnesium	194	187	174	179	195	187	NA	NA
	Manganese	3.6	1.7	0.7	1.3	4.3	1.7	120	NA
	Mercury	<0.05	<0.05	<0.05	<0.05	<0.05	<0.05	1.0	NA
	Molybdenum	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	NA	NA
	Nickel	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	NA	NA
	Potassium	176	145	176	152	175	145	NA	NA
	Selenium	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	50	NA
	Silver	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	NA	NA
Sodium	1630	1510	2000	1620	1620	1580	NA	≤ 200,000	
Zinc	3.5	<3.0	6.8	<3.0	<3.0	<3.0	NA	≤ 5000	

**NA** – No Current Guideline Available **MAC** – Maximum Allowable Concentration **AO** – Aesthetic Objective  
**ALARA** – As Low As Reasonably Achievable <sup>1</sup>Canadian Drinking Water Quality Guidelines



## Bacteriological Quality

The bacteriological monitoring conducted regularly by the City includes testing for heterotrophic plate count (HPC), Total Coliform and E. Coli.

### Heterotrophic Plate Count

Heterotrophic plate count (HPC) is measured to monitor the system for early bacterial re-growth in the water distribution system. The annual average levels of HPC have been decreasing over the last twenty years (Figure 6). While bacteriological re-growth in the late summer and fall period is still occurring (due to warmer water temperatures), it is to a much lesser extent than in previous years. Continued efforts in unidirectional flushing of watermains and maintaining a free chlorine residual objective of 0.2 mg/L helps to keep the HPC numbers below guideline levels of 500 CFU.

### Total Coliform and E. Coli

For a waterworks system to be in compliance, the potable water sample must meet the following standards set out in Schedule A of the *British Columbia Drinking Water Protection Regulations* for the parameter tested (Table 4).

Overall, the bacteriological water quality complied with the *BC Drinking Water Protection Regulations* (Figure 7).

With respect to E. Coli, no samples were found to contain any E. Coli bacteria.

With respect to Total Coliform Bacteria, five (5) samples were found to contain 1 CFU/100 mL. But at no time did the percentage of samples that tested positive for total coliform exceed the 10 per cent stipulated in the *British Columbia Drinking Water Regulations*. Furthermore, none of the samples that tested positive for total coliform contained more than 10 coliform bacteria per 100 mL.

As a standard protocol, any sample with greater than 1 Total Coliform would result in resampling. Any sample with greater than 10 Total Coliforms would result in a follow-up with FHA and immediate flushing of applicable watermains and resampling.

For a complete list of results by sampling locations, see Appendix A.

<b>TABLE 4: SCHEDULE A (WATER QUALITY STANDARDS FOR POTABLE WATER) OF THE B.C. DRINKING WATER PROTECTION REGULATION</b>	
PARAMETER	STANDARD
Fecal Coliform bacteria	No detectable Fecal Coliform bacteria per 100 ml
<i>Escherichia Coli</i> (E. Coli)	No detectable <i>Escherichia Coli</i> per 100 ml
Total Coliform bacteria	a) No more than 10 per cent of the samples in a 30 day period should be positive for Total Coliform bacteria when more than one sample is collected. b) No sample should contain more than 10 Total Coliform bacteria per 100 mL






Figure 6 – Improvements in Drinking Water Distribution System (1998-2021)




Figure 7 – City of Burnaby – 2021 Results of Bacteriological Analyses of Potable Water Samples Compliance with BC Drinking Water Protection Regulation Provided by Metro Vancouver



## WATER UTILITY INCIDENT RESPONSE PLAN

In the event of major emergencies or disasters, the Engineering Department is responsible for restoring and maintaining water utility operations. Furthermore, this will ensure that water quality, quantities and pressures are sufficient for the distribution of drinking water and effective fire-fighting. The Water Utility Incident Response Plan is the Engineering Department's action plan to ensure compliance with the legislated requirements under the *BC Drinking Water Protection Act and Regulation*. Should water utility service be diminished by an emergency or disaster, this plan will assist in reducing the impact and ensuring orderly response.





## CONCLUSION

In partnership with Metro Vancouver, the City of Burnaby consistently delivers clean, safe and aesthetically pleasing drinking water to residents, businesses and visitors in Burnaby. In 2021, the physical, chemical, and bacteriological characteristics of the drinking water continued to be of high quality and in compliance with applicable regulations and guidelines.



